

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003		3. EFFECTIVE DATE 9/20/12		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 12-0091	
6. ISSUED BY CODE		mks		7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				(X) X		9A. AMENDMENT OF SOLICITATION NO. N40085-12-R-0091	
CODE						9B. DATED (SEE ITEM 11) 9/13/12	
FACILITY CODE						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
 12-0091, HVAC/DHW Energy Improvements Various Facilities Hadnot Point

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: On Drawing E-501 RCP General Note 1, in reference to the "Ceiling Tile Repair and Replacement" Does "20% of each Space" refer to the entire building or just the areas we will be working in?
 1. Answer: The undamaged 2x2 ceiling tiles in the corridor shall be salvaged and used to replace up to 20% of the damaged tiles encountered throughout the entire building.

2. Question: Can the CCD be extended 90 days to a total CCD of 540 days to allow for submittals and equipment delivery?
 2. Answer: Yes. The CCD is hereby changed from 450 days after award to 540 days after award.

3. Question: In Attachment I, hazardous materials inspection report shows AB throughout the crawl space of building 13. The drawings direct us to remove a section of the existing domestic hot water line and tie into the existing domestic hot and cold lines in the crawl space to service new water heater. Should we include removal of AB throughout the crawl space of building 13 or only remove the area that is in conflict with our scope of work?
 3. Answer: The only area of concern should be the insulation on the pipe in question. Remove the area in conflict.

4. Question: Building 219 drawing M-106A shows an existing water heater in the building. There are no plumbing drawings or diagrams for the water heater installation for building 219, but there is an electric hot water heater listed on the schedule on drawing M-106C. Please advise if the existing hot water heater is to remain or are we to supply a new hot water heater and piping?
 4. Answer: The existing domestic hot water heater in Building 219 shall remain. Ignore the water heater schedule on sheet M-106C.