

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003	3. EFFECTIVE DATE 08/23/12	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0207	
6. ISSUED BY CODE	eaw	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0207
			X	9B. DATED (SEE ITEM 11) 08/09/12
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

11-0207, Repair Flight Simulator Facility, Bldg AS320

The date and time for receipt of proposals is hereby changed to 1500 hours on 27 August 2012.

-- See Continuation Page --

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

**Q1:** In order to maintain the window integrity as blast tested system and in compliance with the whole window u-value .32 and STC 41 specified in section 085113; we recommend using spandrel insulated glazing or frosted interlayer in lieu of architectural panels for the windows. Blast window systems have not been tested as an assembly using architectural glazing panels and storefront systems will not meet the thermal values as specified in 085113. Will spandrel insulated glass or a frosted interlayer be acceptable in lieu of architectural panels?

**A1:** Delete the Insulated Architectural Panels and provide Spandrel Insulated Glazing.

**Q2:** Sheet M-5, General note A-7 states "EXPOSED DUCTWORK TO BE MILL PHOSPHATIZED, CLEAN AND READY FOR PAINTING BY CONTRACTOR, SEE SPECS FOR INSULATION NOTE APPLIES WHERE INDICATED ON PLANS" There seems to be no specific note on the plans indicating painted ductwork or insulation for such. The insulation spec only mentions mineral fiber insulation with an all purpose jacket suitable for painting in exposed areas.... What are we to go by?

**A2:** Ductwork in areas 105, 108, 110, 111, 114, 120, & 134 is exposed and should be painted. Area 134 shall be a round duct with phosphatized mill finish. Other exposed ductwork shall be insulated with a jacket suitable for painting as specified.