

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002	3. EFFECTIVE DATE 08/21/12	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0207	
6. ISSUED BY CODE eaw	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6			
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0207
			X	9B. DATED (SEE ITEM 11) 08/09/12
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

11-0207, Repair Flight Simulator Facility, Bldg AS320

-- See Continuation Page --

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Q1: In reference to the government supplied propane tank on drawing M-3, where will the meter be located and what piping will the contractor be responsible for? Please advise.

A1: A meter will not be required for the propane tank. Contractor to provide all piping, valves, and regulators for the entire system.

Q2: It looks like "Computer Room 3 Unit Schedule" on M-6 is cut off and leaving out information on the condenser. Please provide the rest of that schedule.

A2: Outdoor Unit Electrical: 460V/3 phase; FLA = 5.2, WSA = 5.7, OPD = 15.
All four notes listed under the schedule apply.

Q3: Finish Schedule on Drawing A-1 indicates new acoustical ceiling & suspension system throughout. Drawing M-1, General Demolition Note "F", remove Lay-In Ceiling, reinstall ceiling when work is complete, replace damaged ceiling tiles. Are we to install new ceiling & suspension system or reinstall existing?

A3: Provide new acoustical ceiling tile system as scheduled in architectural drawings and as specified. Disregard drawing sheet M-1 General Demolition Note "F" reference to Lay-In Ceiling.

Q4: Drawing M-1, General Demolition Note "E", states that existing equipment is to be removed and stored on site. What equipment is to be stored?

A4: Disregard drawing sheet M-1 General Demolition Note "E" stating that existing equipment is to be removed and stored on site. Contractor is to remove equipment abandoned by work in this project and dispose of properly. Refrigerants, if any, are to be captured and turned over to the Government in accordance with specifications.

Q5: Can contractor use base landfill for construction / demo debris?

A5: Contractor may not use the base landfill. The contractor is responsible for hauling construction debris to an off base landfill.

Q6: RFP list 360 contract completion date. Specification Section 180 days. Which is correct?

A6: 360 days is correct. Follow phasing plan as outlined in Specification Section 01 11 00.

Q7: M-2 shows a PCP-1 and HX-1 tag in the pump room. However there is no schedule for either and it isn't shown on the large detail on M-3. Does this design require PCP-1 or HX-1? If so, could engineer provide schedule.

A7: PCP-1 and HX-1 do not apply. Delete from the drawings.

Q8: What type of paint coating is required for painting of concrete floors?

A8: Concrete floors: Epoxy, gloss (Only paint previously painted concrete floors. Apply concrete sealer on all others.)

Existing; MPI REX 3.2C-G6 (Gloss)

Primer: MPI 77;

Intermediate: MPI 77;

Topcoat: MPI 77;

System DFT: 5 mils

Q9: CP-1, 2, and 3 are scheduled for 175 gpm @ 15' Head (M-3). Should this read 175 GPH? Typically, we don't see Condensate Pumps moving 175 gpm. Please verify.

A9: CP-1, CP-2 and CP-3 should have flow indicated as 175 GPH, not 175 GPM.

Q10: HC-1, 2. These coils are selected outside of AHRI ratings. Max face velocity of a hot water coil shall be less than 1200 fpm. These coils are 1392 fpm. Additionally, to meet the pressure drop that is scheduled we would require a coil double the size. Can you request the engineer verify this schedule is correct?

A10: Revise coils sizes to the following:

HC-1, HC-2: 60x42, 17.5 sq. ft. face area, air, water flows and pressure drops unchanged.

HC-3, HC-4: 36x36, 9.0 sq. ft. face area, air, water flows and pressure drops unchanged.