

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004		3. EFFECTIVE DATE 9/21/12	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 12-0091
6. ISSUED BY CODE		CODE	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521			See Item 6	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-12-R-0091
			X	9B. DATED (SEE ITEM 11) 9/13/12
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  
 12-0091, HVAC/DHW Energy Improvements Various Facilities Hadnot Point

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: In spec section 23-07-00-Insulation of Mechanical Systems, page 11, piping insulation table instructs us to use flexible unicellular insulation on domestic cold and hot water lines. Flexible unicellular insulation is not a standard insulation used on domestic hot and cold water lines on Camp Lejeune. In past projects standard insulation is fiberglass for domestic hot water and cell glass for domestic cold water. Please advise if flexible unicellular insulation will be acceptable or will fiberglass/cell glass be required?

1. Answer: Provide Mineral Fiber insulation for above ground Domestic Hot Water piping. Provide 1" thick insulation for pipes up to 3" diameter and 1.5" thick insulation for piping greater than 3" diameter.

Provide Cellular Glass or Polyisocyanurate insulation for above ground Domestic Cold water Piping. For Cellular Glass insulation provide 1.5" thick insulation. For Polyisocyanurate insulation provide 1" thick insulation.

2. Question: Bld 1107 states to provide new panel M, there is no panel schedule for this panel. Please provide a panel schedule for this panel.

2. Answer: Provide the two breakers as stated in note 5 and 6 (1-3 pole 20amp & 1-2 pole amp)

3. Question: What are voltages of existing panels that we are to replace breakers?

3. Answer: 120/208v/3 phase

4. Question: What are voltages of disconnects that are to be replaced?

4. Answer: 208v

5. Question: What are existing panel types that we are to connect new circuits to?

5. Answer: 225amp panel boards

6. Question: Sheet E103 does not indicate location of existing panel A or where new panel M is to be installed

6. Answer: Panel M is to be located in room 102 and the existing panel A is located on the corridor wall of room 107.