

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0005		3. EFFECTIVE DATE 05/28/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0207
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO.
			X	N40085-10-R-0207
				9B. DATED (SEE ITEM 11) 05/12/10
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

10-0207, P-725, Upgrade Fuel Pump Station MCAS New River

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Reference: Electrical Drawings E-001 thru E-602

Question: After a visit to the site, the electrical contractors have found several electrical conduits running underneath the existing access platform. These continue on either to the fuel off-loading areas or to the tanks. These conduits are not addressed anywhere in the electrical drawings. We only have electrical details for pump power and lighting on the new pad. Are these existing conduits to be removed, relocated, replaced, or ignored. It seems that several of them may have to be removed for the soil excavation to proceed. Please advise.

1. Response: The electrical conduits provide power to system controllers and must remain in place.

2. Reference: Temporary Pump Station Amendment Sheet G-004 - Contaminated Soils/Hazardous Materials - Paragraph 4 "B. Existing pipe coating systems have been determined to contain a lead concentration above the laboratories minimum detection limit and shall be handled in accordance with specifications section 02 83 13.00 20 'Lead In Construction'."

Also see Sheet M-404 - Detail C2 - Temporary Pump Station Notes on this detail show the reuse of existing pump assemblies #3 & #4, existing pressure relief valve, and ten existing gate valves.

Question: How are we to reuse all these existing components for the temporary pump station if they are coated in lead paint?

2. Answer: Reuse the existing pump assemblies as described in the temporary pump station amendment. All portions of the pump station that are being reused were designed to be disconnected at flanges, with no cutting or welding of the existing assemblies required for them to be reused. All piping used for the temporary pump station that will require welding must be new, not reused.

3. Reference: Specification Section 33 52 43.00 20 - Paragraph 2.5.1 Process for Carbon Steel

Question: This section calls for x-ray (radiographic) testing of 10% of field welds. In the past, it has been nearly impossible to perform x-ray testing in the field because the contractor needs permission to bring the radioactive devices onto the base, and most times the main gate will not let them through. Will ultrasonic testing of 10% of field welds be considered and acceptable alternative to radiographic testing for this project? Ultrasonic has always been accepted in the past for the testing of underground steam & condensate piping field welds.

3. Answer: Follow the requirements listed in the Specs; use Radiographic X-ray. Contact the OICC to get permission to bring the radiographic equipment on base.