

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0010		3. EFFECTIVE DATE 06/09/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0207	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-10-R-0207
				X	9B. DATED (SEE ITEM 11) 05/12/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

10-0207, P-725, Upgrade Fuel Pump Station MCAS New River

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: Reference: Specification Section 05 21 19 OPEN WEB STEEL JOIST FRAMING
A painting/coating is not specified for the steel joist framing. Should it be galvanized based on the STRUCTURAL STEEL Specification Section 05 12 00 Paragraph 2.4?

1. Answer: The steel joist framing must be galvanized in accordance with Section 05 12 00.

2. Question: Reference: Specification Section 09 97 13.27 EXTERIOR COATING OF STEEL STRUCTURES Paragraph 1.4.6.8 Qualifications of Coating Contractors
This spec section requires that all coating contractors have the ISO-9001 or SSPC-QP-1 certification. This requirement limits this work to only one area contractor and eliminates all regular base painting contractors from performing this scope of work. Can this requirement be lifted for this project?

2. Answer: No, this requirement can not be lifted.

3. Question: How do we excavate two feet below existing water table without dewatering?

3. Answer: The 2 feet into water table is actually 2 feet below the top of the vadose zone and is an estimated goal. The intent is to make sure the contractor excavates into the water table, which may be less than 2 feet. The 2 feet value should be used for estimating quantities since it will be the maximum depth to be excavated to. Also, the contractor must excavate in a manner in which the bucket of the excavator transects the entire targeted depth. This will allow the "wet" soils to be mixed with the dry soils. The contractor must not excavate in a manner in which a vertical interval such as 1 foot at a time is removed. An environmental professional provided by the government will be on site to provide guidance and to confirm that excavations extend to the appropriate horizontal and vertical boundaries. This professional may also need to take a few soil samples at certain locations. Backfilling of excavation must be initiated with #57 stone or other suitable coarse aggregate to bridge any standing water in the excavation, then covered with filter fabric, and then filled with suitable backfill materials.

4. Question: Contract documents call for an excavated area of 83' x 53' x 2' below water table. Water table stated at 5' to 7' below grade. If water table averages at 6' below grade, excavation will average 8' below grade. Based on these dimensions, excavation will total 1303.4 cubic yards, not 602 cy as stated. Is there ample room at the site for a containment this size?

4. Answer: Yes, there is room inside the Fuel Farm fence line. Soil can be staged along the fence line.

5. The following is provided to clarify the excavation depth:
Once the contractor "hits" the water table, the contractor must dig 2 feet into the water table. The water table is estimated to be 5 to 7 feet below grade.

6. On the "Scope of Work MILCON Soil Excavation", Note #1 of "Section D. Excavation Activities" replace note with: "The contractor will excavate an area approximately 50 feet wide by 65 feet long to a depth of 2 feet below the existing water table; the water table is estimated at 5 to 7 feet below grade. Excavated soil will be placed on a containment pad and sampled for disposal."