

**NAVFAC  
SPECIFICATION**

**CP12024M/CP12024R  
FACILITIES ENERGY  
REPAIRS BLDG-131  
MCAS Cherry Point, NC**

**AMENDMENT #0003**

## **IMPORTANT**

**This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.**

**If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.**

2. AMENDMENT/MODIFICATION NO. <b>0003</b>	3. EFFECTIVE DATE <b>8/28/2012</b>	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
--	---------------------------------------	----------------------------------	--------------------------------

6. ISSUED BY <b>CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533</b>	Code <b>N40085</b>	7. ADMINISTERED BY (If other than item 6.)	Code
--	--------------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  <p style="text-align: center;"><b>AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL</b></p> CODE _____ FACILITY CODE _____	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION
	<input type="checkbox"/>	9B. DATED (SEE ITEM 11)
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
	<input type="checkbox"/>	10B. DATED (SEE ITEM 13)

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

---

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor  is not  is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

**CP12024M/CP12024R FACILITIES ENERGY REPAIRS BLDG-131 MCAS Cherry Point, NC**

1. The purpose of this amendment is to provide the following information:

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

**QUESTION:**

Both specification sections 085113 part 1.11.4 & 088100 part 2.2 call for the whole window (frame and glazing) to meet a U-.35 per NFRC 100. This will not be attainable with the window frame type as detailed C4 & B5/A601 and seems somewhat irrelevant considering the mounting method. Can the NFRC 100 requirement be deleted allowing minimum U-.35 for center of glass similar to part 2.2.1 088100?

**Answer:**

Delete the NFRC 100 requirement. A minimum U-.35 for center of glass similar to part 2.2.1 088100 is acceptable.